



Sue Masten <cdbg@fairhaven-ma.gov>

Prelim Subdivision -4 Earle Street, Map 31A, Lot 453

Todd Correia <tcorreia@fairhaven-ma.gov>
To: Sue Masten <cdbg@fairhaven-ma.gov>

Wed, Jan 7, 2026 at 12:05 PM

Good Morning,

Regarding the development of 4 Earle Street, MAP 31A, Lot 453, this department has no objections as long as the proposed development includes a cul-de-sac or hammerhead, as outlined in Fairhaven Code. Additionally, a hydrant must be installed at the cul-de-sac or hammerhead, per Fairhaven Code and the water department's requirements.

As this development is a side street off Route 6, it is crucial to ensure there is adequate water access and the ability to turn around without backing into or laying a hose line across Route 6 ([Huttleston Ave](#)).

Please let me know if you have any questions.

Regards,

Todd Correia
Fire Chief
[146 Washington Street,](#)
[Fairhaven MA 02719](#)
[www.fairhavenfire.org](#)
Office: (508) 994-1428
Direct: (978) 763-6107
Fax: (508) 994-1515



[Quoted text hidden]